



Evapodry

Condensate Removal Tray

Suffering from unwanted condensate from your airconditioning unit?

Evapodry can solve this problem by evaporating the condensate from the collection tray under the split system's compressor.

A new and improved control unit ensures a more reliable evaporation process. The probe senses condensate or rainwater that has accumulated in the tray and energises the heating element. When the probe senses that the liquid has evaporated, the heating element is turned off.

The electric heating element, together with its condensate sensing probe, fits inside the collection tray as an integrated unit. All electrical terminations are inside an IP55 rated enclosure.

The condensate collection tray is stainless steel, measuring 400 x 400 x 55mm deep, with the heating element and control box fitted to the front.



Free Phone 1800 025 287 Free Fax 1800 631 235
www.thermalelectric.com.au



Evapodry

Specifications

- Heating Element is rated at 240V 1000W or 2400W
- Enclosure is IP55 rated with weatherproof flexible conduit entry, and termination is by a 1 metre lead with 3 pin plug
- Evaporation rate is one litre per hour (for 1kW unit) or 2.5 litres per hour (for 2.4kW unit) and this may vary dependent upon atmospheric conditions
- Condensate tray is stainless steel 400 x 400 x 55mm deep. Other sizes to order
- Element safety cover fabricated from perforated stainless steel



Ideal for High rise buildings with limited space

The Evapodry tray conforms to health and safety standards in accordance with Plumbing Industry Commission - Section 7 part E.



Probe senses condensate or rainwater and turns on heating element



HEAD OFFICE

7 Buckman Cl
TOORMINA NSW 2452
P: +61 2 6659 6200
F: +61 2 6653 3839
Email: sales@
thermalelectric.com.au

MELBOURNE

4/257 Governor Rd
BRAESIDE VIC 3195
P: 03 8587 6600
F: 03 9580 6333
Email: melbourne@
thermalelectric.com.au

SYDNEY

19/45 Powers Rd
SEVEN HILLS NSW 2147
P: 02 8814 2500
F: 02 9620 9121
Email: sydney@
thermalelectric.com.au

BRISBANE

1/8 Hopper Ave
YATALA QLD 4207
P: 07 5547 3300
F: 07 5540 7194
Email: brisbane@
thermalelectric.com.au

PERTH

9/17 Prowse St
WEST PERTH WA 6005
P: 08 9363 8700
F: 08 9467 1465
Email: perth@
thermalelectric.com.au

MALAYSIA - Enhance Track

9, Jalan Meranti 12,
Meranti Jaya Industrial Park
47120 Puchong, Selangor
P: +603 8063 2281
F: +603 8063 2282
Email: enquiry@enhancetrack.com